

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 2280-2014:0100 Page 1 of 1

CATEGORY: 2280 -- COATING MATERIALS (FLAME SPREAD)

LISTEE: NO BURN INC.1392 High Street, Suite 211, Wadsworth, OH 44281
Contact: William Kish (800) 989-8577 Fax (330) 336-5800
Email: bill@noburn.com

DESIGN: Type No Burn Plus "NB Plus 8 mils wet over OSB" coating material. The No Burn material is sprayed on the surface of the oriented strand board (OSB) with thickness of 8 mils.

RATING: Class A
Flame Spread: 5
Smoke Developed Index: 35

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product label and Intertek label.

APPROVAL: Listed as a coating material for application to OSB surfaces to reduce flame spread. Approval limited to interior wall/ceiling surfaces when the coatings are applied at the rates specified in accordance with the manufacturer's installation instructions. Authority having jurisdiction should be consulted prior to installation.

11-09-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division